

EPO No. 21

Examination Procedure Outline for Retail Motor-Fuel Dispensers Single, Dual and Multi-Product (Except Blenders)

It is recommended that this outline be followed for conventional, single and dual product, power-operated retail dispensers--"gasoline pumps," analog or digital, and consoles. This outline may also be used for multi-product dispensers that share a single hose but not including those that dispense blended products. Nonretroactive requirements are followed by the applicable date in parentheses.

SAFETY NOTES

When excerpting this Examination Procedure Outline for duplication, the "Safety Considerations" section and the "Glossary of Safety Key Phrases" should be duplicated and included with the outline.

The inspector is reminded of the importance of evaluating potential safety hazards prior to an inspection and taking adequate precautions to avoid personal injury or damage to the device. The inspector should read and be familiar with the introductory section on safety found at the beginning of this publication. As a minimum, the following safety precautions should be noted and followed during the inspection. Definitions of each reminder are found in the "Glossary of Safety Key Phrases" at the back of this publication.

Safety policies and regulations vary among jurisdictions. It is essential that inspectors or servicepersons be aware of all safety regulations and policies in place at the inspection site and to practice their employer's safety policies. The safety reminders included in this EPO contain general guidelines useful in alerting inspectors and servicepersons to the importance of taking adequate precautions to avoid personal injury. These guidelines can only be effective in improving safety when coupled with training in hazard recognition and control.

Clothing

Material Safety Data Sheets (MSDS)

Electrical Hazards

Nature of Product

Emergency Procedures

Personal Protection Equipment

Eye Protection

e.g., Safety Shoes, Safety Aprons, Gloves,
Barrier Cream, etc. if deemed necessary

Fire Extinguisher

Safety Cones/Warning Signs

First Aid Kit

Static Discharge

Grounding

Switch Loading

Ignition Sources

Traffic

Lifting

Transportation of Equipment

Location

also: **Wet/Slick Conditions, Chemicals, Hazardous Materials,
Petroleum Products, Obstructions**

EPO No. 21

Inspection:

Safety First !!!

Check the inspection site carefully for safety hazards and take appropriate precautions.

Learn the nature of hazardous products used at or near the inspection site – obtain and read copies of MSDS's.

Know emergency procedures and location and operation of fire extinguisher and emergency shut-offs.

Post safety cones/warning signs and be aware of vehicular and pedestrian traffic patterns.

Use caution in moving in wet, slippery areas.

Use personal protection equipment and clothing appropriate for the inspection site.

Open both sides of dispenser to allow fumes to dissipate before proceeding with the inspection of the dispenser.

If leaks, spills, or exposed wiring cause hazardous testing conditions it is recommended that the testing be discontinued until the unsafe conditions are corrected.

Be sure that a first aid kit is available and that it is appropriate for the type of inspection activity.

H-44 General Code and Liquid-Measuring Devices Code References

1. General considerations
 - Selection..... G-S.3., G-UR.1.1., G-UR.1.2., G-UR.1.3.
 - Installation..... G-S.2., G-UR.2.1., G-UR.2.2., UR.2.1., UR.2.4.
 - Position of equipment..... G-UR.3.3.
 - Accessibility..... G-UR.2.3.
 - Assistance..... G-UR.4.4.
 - Use and maintenance..... G-UR.3.1., G-UR.4.1., G-UR.4.2., UR.3.5.
2. Indicating and recording elements.
 - Design..... S.1.1.
 - Units..... S.1.2.1., S.1.2.3.(a)
 - Readability..... G-S.5., G-S.6.(1/1/77), G-S.7., S.1.4., S.1.5.
 - Values of intervals..... G-S.5.3., G-S.5.3.1.
 - Indication of delivery..... S.1.6.1.,
 - Money-value divisions
 - Analog..... S.1.6.5.1.
 - Digital..... S.1.6.5.2.
 - Auxiliary indications..... S.1.6.5.3. (1/1/85)
 - Unit Price and product identity..... S.1.6.4.1.(a), S.1.6.4.2., UR.3.2.
 - Multiple unit price dispensers..... S.1.6.4.1.(b) (1/1/91), S.1.6.5.(a) (1/1/91), S.1.6.5.4. (1/1/91), UR.3.3.

EPO No. 21

Inspection (cont.):

- | | |
|--|---|
| Advancement and return to zero | S.1.3., S.1.6.3., UR.3.1. |
| Recorded representations, point of sale systems | S.1.6.7. (1/1/86) |
| Provision for sealing | G-S.8. (1/1/90), G-UR.4.5.,
S.2.2.(a&b), S.2.2.(c) (1/1/95)
Table S.2.2. (1/1/95) |
| 3. Marking | G-S.1., G-UR.2.1.1., G-UR.3.4.,
S.4.1., S.4.4.1. (1/1/85), S.4.4.2.
(1/1/03) |
| 4. Measuring elements. | |
| Air eliminator vent, if self-contained dispenser | S.2.1. |
| Security seal on adjusting mechanism | G-UR.4.5. |
| 5. Discharge hose-retail | S.3.1., S.3.2., S.3.3., S.3.5.(b),
S.3.6., UR.1.1. |
| Marinas and Airports | UR.1.1.2. |
| 6. Totalizers | S.5. (1/1/95) |

Pretest Determinations:

- Tolerances.
 Applicable requirements
- Product storage identification

Test Notes:

Wear appropriate personal protection equipment such as petroleum-resistant, nonskid safety shoes (to prevent possible injury from spills or slipping on slick surfaces), protective clothing, and eye protection to prevent injury from splashed product.

Do not leave an activated dispenser unattended !

- If test measure is dry, add 16.4 milliliter (one cubic inch) to gauge reading to allow for amount of liquid required to "wet" measure.
- Hand held test measures require a 30-second (± 5 s) pour followed by a 10-second drain, with the measure held at a (10 to 15) degree angle from vertical.
(see NIST HB 105-3, Specifications and Tolerances for Graduated Neck Type Volumetric Field Standards, 1997, Section 7).

EPO No. 21

Test Notes (cont.):

Ground test measure properly and only use a metal funnel when returning product to storage.

3. To determine proper operation of totalizers, read and record the totalizer indications before and after all test drafts.....S.5. (1/1/95)
4. After each test draft:
 - a. print ticket if device is so equipped.....G-S.5.6., S.1.6.7. (1/1/86), UR.3.4.
 - b. check price computations on all indicators
(including consoles) and on recorded representations.....S.1.6.5.(a) (1/1/91)
digital equipmentG-S.5.5.
analog equipmentS.1.6.5.(b), N.4.3.2.
 - c. check for agreement between indicators.....G-S.5.2.2., S.1.6.6.(a),
S.1.6.6.(b) (1/1/88)
5. Verify, after a delivery is completed, that the quantity and total price are displayed for at least 5 minutes or until the next transactionS.1.6.5.5. (1/1/94)

Test:

Use proper lifting techniques when lifting test measure !

Be aware of and attempt to eliminate potential ignition sources in or near the inspection site.

Be aware of vehicular and pedestrian traffic when moving between dispenser and storage tanks.

1. Normal test—full flow, basic toleranceN.1.1., N.2., N.3.4., N.4.1.,
T.2., UR.2.2.
At the beginning of the first delivery, check for suppressed values.S.1.6.1.
If first test result is at or near the tolerance limit, repeat this test.T.3., N.4.1.2.

Petroleum Product Sampling¹

¹ When taking gasoline samples from single hose multi-product dispensers, the samples should be collected after an observed sale of the particular grade or product to be tested, or sufficient product should be purged from the hose to ensure the sample is representative of the grade or product being sampled. The National Conference on Weights and Measures policy on procedures for taking samples for octane verification is as follows: **“A minimum of a liter (0.3 gallon) of engine fuel shall be flushed from the dispensers before taking a sample for octane verification. This flush shall be returned to the storage tank containing the lowest octane.”** (see NCWM Publication 21, Petroleum Products Sampling Procedures and Safety Manual, August 1997).

EPO No. 21

Test (cont.):

2. Special test--slow flow, basic toleranceN.4.2., N.4.2.2., T.2.
3. RFI/EMI test (electronic equipment only)G-N.2., G-UR.1.2.,
Radio Frequency Interference (RFI)G-UR.3.2., G-UR.4.2.
Electromagnetic Interference (EMI)
4. Check effectiveness of anti-drain meansS.3.7.
5. Check effectiveness of zero-setback interlock.S.2.5.
On equipment with remote pumping systems, activate one dispenser and check all
others operated by the same pump to make certain they will not operate without
activating the individual starting levers.
6. Power loss test.....S.1.6.2.1.(1/1/83), S.1.6.2.2.
(1/1/83)
Check with your supervisor before requiring shutdown of power to equipment
under test.
7. Security means
a. check for / apply security sealG-UR.4.5.
b. record audit trail informationS.2.2.(c), (1/1/95)
Table S.2.2. (1/1/95)

Record the number of gallons of product dispensed during test on the official report.

Avoid switch loading!
Test devices dispensing low-vapor pressure products (e.g., diesel fuel, kerosene)
before testing devices dispensing high-vapor pressure products (e.g., gasoline).

After all equipment at a location has been tested, review results to determine compliance
with equipment maintenance and use of adjustmentsG-UR.4.1., G-UR.4.3.

Take precautions to isolate equipment when
transporting it to avoid exposure to hazardous fumes.

THIS PAGE WAS LEFT BLANK INTENTIONALLY